



SC COMPANIA REGIONALA DE APA BACAU SA

Str. Henri Coanda, nr. 2 – Bacau J4/789/27.09.2010/ CUI:RO 27429315 Capital social: 24.047.170 lei COD CAEN: 3600	Tel:0372-401.301/Fax:0234-55.11.75 web: www.apabacau.ro e-mail: manager@apabacau.ro Banca: BRD Bacau Cont: RO13BRDE040SV60027870400	 <p>RINA este Membru al Federatiei CISQ</p> <p>RINA SIMTEX ORGANISMUL DE CERTIFICARE</p> <p>ISO 9001 · ISO 14001 · ISO 45001 sistem integrat Certificat</p> 
--	---	---

BULETIN DE INFORMARE CU PRIVIRE LA CALITATEA APEI

Prelevare: Retea distributie Mun. Bacau
Data: 23.03.2023

Nr. crt.	Parametrii analizati	UM	Metoda de analiza standardizata	Valori CMA conform OG nr.7 / 2023	Rezultate obtinute
1.	Turbiditate	N.T.U.	SR EN ISO 7027/2001	≤ 5	0,41
2.	pH	unit.pH	SR ISO 10523/ 2012	6,5 ÷ 9,5	7,30
3.	Conductivitate electrică	$\mu\text{S}/\text{cm}$	SR EN 27888/ 1997	2500	408
4.	Suma de calciu și magneziu (duritate)	grade germane	SR ISO 6059/ 2008	minim 5	10,67
5.	Mangan	$\mu\text{g}/\text{l}$	SR ISO 6333/ 1996	50	40
6.	Amoniu	mg/l	SR ISO 7150-1/ 2001	0,50	< 0,013
7.	Nitrați	mg/l	SR ISO 7890-3/ 2000	50	4,78
8.	Nitriți	mg/l	SR ISO 6777/2002 / C91/ 2006	0,50	< 0,0083
9.	Clor rezidual liber in rețeaua de distribuție	mg/l	STAS 6364 / 1978	$\geq 0,1 - \leq 0,5$	0,33
10.	Aluminiu	$\mu\text{g}/\text{l}$	SR ISO 10566 / 2001	200	19

Rezultatele reprezinta media zilnica a probelor de apa analizate.

Conform analizelor fizico-chimice si microbiologice efectuate, apa este potabila si indeplineste prevederile OG nr 7 / 2023 privind calitatea apei potabile pentru indicatorii analizati.